

FORM-D

Form of Licence under Sub-section(1) of section 6 of the Madras Public building (licensing) Act 1965 (Madras Act 13 of 1965) referred in Rule 6 of the Madras Public Building (Licensing) Rules 1966.

LICENCE

Licence No. 02/2026/B3

Challan No.20260113015020

Fee. Rs.1000/- SBI Salem

Dt. 13.01.2026

Registration No.K.Dis. 47/2026/B3/ Dated.13.01.2026.


Licence is hereby granted to **THE PRINCIPAL, ZZEN INDIA PUBLIC SCHOOL, WARD - X, BLOCK-5, T.S.No. 231/2 (Old S.No. 57/2) SEELANAICKNPATTI BYE PASS, SALEM SOUTH TALUK, SALEM DISTRICT-636 201.** for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned hereunder:-

1. The period of validity of the Licence shall be from **24.11.2025 to 23.11.2028.**
2. The building should be used for the purpose for which Licence has been granted.
3. The number of persons to be accommodated in the building should not exceed the number noted in Col. 3 of the statement in the licence at a time.
4. This licence will not be valid for any addition or alteration made to this building before the date of expiry of the period **23.11.2028.** of the licence.
5. Fresh licence will have to be obtained if any additions or alteration are made to this buildings.

Tahsildar
Salem South.

STATEMENT OF ACCOMPANY THE LICENCE


Location of the building (Door No.Street No. and Name of Place)	Purpose for which the building is licensed to be used as a public building	No.of Persons to be accommodated
WARD - X, BLOCK-5, T.S.No. 231/2 (Old S.No. 57/2) SEELANAICKNPATTI BYE PASS, SALEM SOUTH TALUK, SALEM DISTRICT-636 201.	ZZEN INDIA PUBLIC SCHOOL (Education Purpose)	Maximum Accommodation Students - 1500 Teaching Staffs - 80 Total 1580



Tahsildar
Salem South.


CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKNPATTI BY-PASS,
SALEM-636 201.


PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKNPATTI BY-PASS,
SALEM-636 201.


13/01/2026

Er. S. RAMALINGAM,
ME.,F.I.V.,M.I.E.,

☎ : 94421 - 32328

AARVY ASSOCIATES

No. 5/1, Surya, (Backside of Vinayaka School), Lakshmi Road,
Advaitha Ashramam Road, Fairlands, Salem -4.

☎ : 0427- 4030328 ☎ : 98427 - 32328 ☎ : 94433 - 32328
email : aarvyassociatessalem@gmail.com



- ☐ Approved Panel - Valuer for Nationalized & Scheduled Banks
- ☐ Regd. Engineer -Class IA of Tamil Nadu Public Buildings Act
- ☐ Chartered Civil Engineer
- ☐ Registered Valuer- IBBI (Companies Act)

- ☐ Registered Engineer-SLPA
- ☐ Registered Valuer of Income Tax
- ☐ Approved Panel Valuer for IOCL, BPCL, HPCL

GOVT. APPROVED VALUERS

BS / 2025 / 60 DT. 24-11-2025

BUILDING SAFETY CERTIFICATE

It is certified that the School Building **ZZEN INDIA PUBLIC SCHOOL** at Ward-X, Block-5, T.S.No.231/2 (Old S.No.57/2), Seelanaickenpatty Bye Pass, Seelanaickenpatty Village, Salem South Taluk, Salem District. Pincode-636201. Tamilnadu is having Block(s) / Floor(s) as per details below.

Details of Blocks in School	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in The Block	Zero Basement G + 2	Nil	Nil	Nil	Nil	Nil

The building is owned / occupied by **ZZEN INDIA PUBLIC SCHOOL** have complied with the Building Safety requirements in accordance with National Building code Rules and verified by the officers concerned of **Er.S.RAMALINGAM M.E.F.I.V MIE.,**Registered Engineer of Tamilnadu No. D.DIS/11081/2000/H1 CLASS 1 A on 24.11.2025 in the presence of **Mr.P.SHANMUGASUNDARAM** Correspondent of **ZZEN INDIA PUBLIC SCHOOL** and that the Building / premises is fit for occupancy for running school upto Class XII with effect from 24.11.2025 for a period of 3 Years from 24.11.2025 to 23.11.2028 in accordance with rule and subject to compliance of the specific conditions as appended.

1. Building is to be maintained properly / Regularly as per NBC code / Norms.
2. New Building Safety Certificate shall be obtained if any addition / alternation is carried out.

Issued on 24.11.2025 at Salem by Er.S.Ramalingam Licence
Engineer License No. D.DIS/11081/2000/H1

S. Ramalingam
24-11-2025
Signature with Seal

Er. S. RAMALINGAM M.E.F.I.V., M.I.E.,
Chartered Engineer M/108321/4 - 1993
Class IA Panel Engineer,
(TN Public Buildings Act.)
5/1, Surya Apartments, Lakshmi Road,
Advaitha Ashramam Road,
Fairlands, Salem-636 004.

[Signature]

CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

D. Pothurames
PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

PROCEEDINGS OF THE COLLECTOR, SALEM.

PRESENT: DR. J. RADHAKRISHNAN, I.A.S.,

D.Dis. 11081/2000/H1,

Dated: 6.11.2001

Su b:- Tamil Nadu Public Buildings Licensing Act 1965 - Inclusion of the name of Thiru. S. Ramalingam in the panel of private practising Engineers - under Class - IA category in Salem District, - Regarding.

- Ref:- 1. Thiru. S. Ramalingam petition dated: 7.2.2000.
2. Salem Superintending Engineer (PWD) Lr.No. 74M/CO22/EVA2/2001, dated: 19.2.2001.
3. This Office Proceedings D.Dis. 24947/94 /H2, dated: 31.3.94.
4. Chennai Chief Engineer (General) PWD Lr.AEE/T1/JE/46507/2001, dated: 24.9.2001.
....

ORDER:

Thiru. S. Ramalingam, B.E., a Private Engineer, has applied for the inclusion of his name under category of Class IA in the panel of private practising Engineers maintained in this office for the purpose of issuing structural soundness certificate for public buildings in Salem District under the rules of Tamilnadu Public Building Licensing Act 1965.

2. The Chief Engineer, Public Works Department (General) Madras in the reference 4th cited has stated that the Board of Engineers in their 414th meeting held on 29.8.2001 have decided that the name of Thiru. S. Ramalingam, B.E., Private Engineer be included under the category of Class IA buildings the cost of which exceeds Rs. 10/- lakhs for the purpose of issuing structural soundness Certificate for public buildings in Salem District under the purview of the Tamil Nadu Public Buildings Licensing Act 1965.

CORRESPONDENT


ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

PRINCIPAL


ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

:: 2 ::


3. In accordance with the instructions issued by the Chief Engineer (General) Public Works Department, Chennai in the reference fourth cited, the name of Thiru. S. Ramalingam, B.E., residing at 79-C1, Sivam Complex, Peramanoor, Salem-7 is included under the category of Class IA (for buildings the cost of which exceeds Rs.10/- Lakhs for the purpose of issuing structural soundness certificate for the Public Buildings in Salem District under the purview of the Tamilnadu Public Buildings Licensing Act 1965.


For Collector, Salem.

To


Thiru. S. Ramalingam, B.E.,
79-C1, Sivam Complex,
Peramanoor, Salem - 7.

Copy to H1 (Stock file)


CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.


PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

Er. S. RAMALINGAM,
ME., F.I.V., M.I.E.,

☎ : 94421 - 32328

AARVY ASSOCIATES

No. 5/1, Surya, (Backside of Vinayaka School), Lakshmi Road,
Advaita Ashramam Road, Fairlands, Salem -4.

☎ : 0427- 4030328 ☎ : 98427 - 32328 ☎ : 94433 - 32328
email : aarvyassociatessalem@gmail.com




- ☐ Approved Panel - Valuer for Nationalized & Scheduled Banks
- ☐ Regd. Engineer -Class IA of Tamil Nadu Public Buildings Act
- ☐ Chartered Civil Engineer
- ☐ Registered Valuer- IBBI (Companies Act)


- ☐ Registered Engineer-SLPA
- ☐ Registered Valuer of Income Tax
- ☐ Approved Panel Valuer for IOCL, BPCL, HPCL

GOVT. APPROVED VALUERS

STATEMENT ACCOMPANYING FORM - A.

- (1). Name of the School : **ZZEN INDIA PUBLIC SCHOOL**
- (2). Door Number of Building : ---
- (3). Location (Street number, Ward number, Name of Place, i.e., Corporation / Municipality / Panchayat / Panchayat Union / Township / Cantonment) : Ward-X, Block-5,
T.S.No.231/2 (Old S.No.57/2),
Seelanaickenpatty Bye Pass,
Seelanaickenpatty Village,
Salem South Taluk,
Salem District. Pincode-636201.
- (4). Year of Construction :
Block-I : 2003 to 2010
(Various Periods)
Toilet Block : 2010
- (5). Approximate cost of Construction as per current Rates : **₹ 1,50,00,000/-**
(Rupees One Crore and Fifty Lakhs Only)
- (6). Purpose which the building is being used or proposed to be used : Educational Purpose -
School Buildings
- (7). Purpose for which the building has hitherto been used : Educational Purpose -
School Buildings


CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.


PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

- (8). Details of Construction of the building (particulars of the foundation soil, specification of the various parts under...) :
- (i). Foundation. : Partly RCC Framed Structure,
Partly Load Bearing Structure,
Partly RR in Cement Mortar
Partly in RCC Column
- (ii). Basement. : Partly RR in Cement Mortar &
Partly Plinth Beam
- (iii). Superstructure. : Brick work in Cement Mortar
- (iv). Floor and Roof.
(are to be given) : Cement Concrete Flooring &
Partly Vitrified tiles flooring
RCC Roofing &
Very Minor Portion GI Sheet Roofing
- (9). Period for which licence is required : 24.11.2025 to 23.11.2028
- (10). Number of persons to be accommodated : Students - 1500
Staff - 80

Dated : 24.11.2025

Signature of the Engineer.

S. Ramalingam
24.11.2025

DECLARATION

Er. S. RAMALINGAM M.E., F.I.V., M.I.E.,
Chartered Engineer M/108321/4-1993
Class IA Panel Engineer,
(TN Public Buildings Act.)
5/1, Surya Apartments, Lakshmi Road,
Advathi Ashramam Road,
Fairlands, Salem-636 004.

We declare that no addition or alteration has to be made or will be made to the existing building or portion of a building for which this application has been submitted. We undertake to obtain fresh license incase any addition or alteration is made, to the existing building or portion of this building. We also undertake to obtain fresh license if the purpose for which the license was granted for the use of the building or a portion of the building originally is damaged or altered subsequently.

Signature of the School Authority
(ZEN INDIA PUBLIC SCHOOL)

[Signature]
CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

D. Pothuvarasu
PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

FORM - B

(Form of Certificate of structural soundness under sub - section (4) of section 4 of the Madras Public Buildings (Licensing) Act, 1965 (Madras Act 13 of 1965), referred to in rule 4 of the Madras Public Buildings (Licensing) Rules, 1966.)

I certify that I have inspected the building mentioned in the statement below and I have satisfied myself that the building is structurally sound to be used as a public building for the purpose noted in the statement.

I. Foundation

- | | |
|---|---|
| i) Depth Below Ground Level | - 4'0" to 6'0" (variable) |
| ii) Nature of Soil met with @ Foundation Level | - Hard Gravel to Medium Rock |
| iii) Pressure at Foundation | - 19t/m ² |
| iv) Probable SBC of the Strata @ Foundation Level | - 20t/m ² - 25t/m ² |

II. Superstructure

- | | |
|---|---------------------------|
| 1. Maximum Stress in the Most Critical Section of Masonry | - 0.34N/mm ² |
| Maximum Stress in the Most Critical Section of Concrete | - 0.60N/mm ² |
| 2. Nature of Masonry | - Safe permissible stress |
| Brick Masonry | - 0.35N/mm ² |
| Concrete RCC | - 3N/mm ² |

The structural soundness of the building has been verified taking into account the loading as per the latest Indians standards 875. A licence may be granted for the period from 24.11.2025 to 23.11.2028 (inclusive).

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS.

Location of the building (Door. No., Street and name of Place)	Age of the building	Purpose for Which the Building can be used.	The period for Which the building will be structurally sound.(4)	Number of Persons to be accommodated.	Area Details
(1)	(2)	(3)	(4)	(5)	(6)
ZZEN INDIA PUBLIC SCHOOL Ward-X, Block-5, T.S.No.231/2 (Old S.No.57/2), Seelanaickenpatty Bye Pass, Seelanaickenpatty Village, Salem South Taluk, Salem District. Pincode-636201.	<u>Block-I</u> Partly - 22 Years Partly - 15 Years <u>Toilet Block</u> 15 Years	Educational Purpose - School Buildings	24.11.2025 to 23.11.2028	Students - 1500 Staff - 80	Refer Annexure

Dated : 24.11.2025

Signature of the Engineer.



S. Ramalingam
24-11-2025

CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

D. Pothuvaran
PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

Er. S. RAMALINGAM M.E., F.I.V., M.I.E.,
Chartered Engineer M/108321/4 - 1993
Class IA Panel Engineer,
(TN Public Buildings Act.)
5/1, Surya Apartments, Lakshmi Road,
Advaita Ashramam Road,
Fairlands, Salem-636 004.

FORM - C.

(Form of opinion under sub - section (1) of section 5 of the Madras Public Buildings (Licensing) Act, 1965 (Madras Act 13 of 1965), referred in rule 5 of the Madras Public Buildings (Licensing) Rules, 1966.)

I have inspected the building specified in the statement below and I have satisfied myself that the building is structurally sound to be used as a public building for the purpose specified in the statement.

I. Foundation

- | | |
|---|---|
| i) Depth Below Ground Level | - 4'0" to 6'0" (variable) |
| ii) Nature of Soil met with @ Foundation Level | - Hard Gravel to Medium Rock |
| iii) Pressure at Foundation | - 19t/m ² |
| iv) Probable SBC of the Strata @ Foundation Level | - 20t/m ² - 25t/m ² |

II. Superstructure

- | | |
|---|---------------------------|
| 1. Maximum Stress in the Most Critical Section of Masonry | - 0.34N/mm ² |
| Maximum Stress in the Most Critical Section of Concrete | - 0.60N/mm ² |
| 2. Nature of Masonry | - Safe permissible stress |
| Brick Masonry | - 0.35N/mm ² |
| Concrete RCC | - 3N/mm ² |

The structural soundness of the building has been verified taking into account the loading as per the latest Indian standards 875. I am therefore of the opinion that a licence may be granted for the period from 24.11.2025 to 23.11.2028 (inclusive).

STATEMENT TO ACCOMPANY THE OPINION REGARDING STRUCTURAL SOUNDNESS.

Location of the building (Door. No., Street and name of Place)	Age of the building	Purpose for Which the Building can be used.	The period for Which the building will be structurally sound.(4)	Number of Persons to be accommodated.	Area Details
(1)	(2)	(3)	(4)	(5)	(6)
ZZEN INDIA PUBLIC SCHOOL Ward-X, Block-5, T.S.No.231/2 (Old S.No.57/2), Seelanaickenpatty Bye Pass, Seelanaickenpatty Village, Salem South Taluk, Salem District. Pincode-636201.	<u>Block-I</u> Partly - 22 Years Partly - 15 Years <u>Toilet Block</u> 15 Years	Educational Purpose - School Buildings	24.11.2025 to 23.11.2028	Students - 1500 Staff - 80	Refer Annexure

Dated : 24.11.2025

Signature of the Engineer.



S. Ramalingam
24.11.2025

[Signature]
CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

D. Dhuruvan
PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

Er. S. RAMALINGAM M.E., F.I.V., M.I.E.,
Chartered Engineer M/108321/4-1993
Class IA Panel Engineer,
(TN Public Buildings Act.)
5/1, Surya Apartments, Lakshmi Road,
Advathi Ashramam Road,
Fairlands, Salem-636 004.

ANNEXURE

Specification

Foundation
Superstructure

Roof
Flooring

Joineries
Wiring

Plastering Works

a). Walls
b). Ceiling

Block - I

(Ground floor, First floor & Second floor)

RCC Column
RCC Column & Brickwork
Cement Mortar
RCC Roof
Ground floor - Tiles,
First & Second floor - Cement Mortar
Country wood & Steel Joineries
Concealed Line

Cement Mortar
Cement Mortar

Block - I (Area details including Corridor)

Ground floor : 13170.44 Sft (RCC Roof)
First floor : 13170.44 Sft (RCC Roof)
Second floor : 13170.44 Sft (RCC Roof)

Specification

Foundation
Superstructure

Roof
Flooring

Joineries
Wiring

Plastering Works

a). Walls
b). Ceiling

Toilet Block

RR in Cement Mortar
Brickwork in Cement Mortar
RCC Roof & GI Sheet Roof
Cement Concrete Mortar finish
Steel Joineries
Concealed Line

Cement Mortar
Cement Mortar

Toilet Block


Ground floor - RCC Roof : 1442.65 Sft
Ground floor - GI Sheet Roof : 238.00 Sft
(Staff Toilet)

General Observation

Whether Fire Extinguisher fixed : Yes, Fire Extinguisher are fixed - 13 Units.
Sand Buckets - 4 Units.
Whether photos of the building enclosed : Yes, Photos are enclosed.
Whether Lightening Arrester fixed : Yes, Lightening Arrester is fixed.
Whether CCTV Cameras are fixed : Yes, 36 Units of CCTV Cameras fixed.

Recommendations

- Recommended to do periodical maintenance of painting works / prevention of Cracks / Dampness / Leakage in Building without fail.
- Recommended to maintain & inspect the various electrical accessories & Fire fighting equipment with proper trained persons.
- Recommended to maintain proper sanitary arrangement & proper collection / disposal of rainwater.



CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.



PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.



DECLARATION

I, S. Ramalingam Son of Late. Shri. R. Subramanian do hereby declare that I posses the qualification and experience specified in the table to rule 11 of the Madras Public Building, (Licensing) Rules, 1966, for issuing the certificates of soundness of the building covered by the certificate.

(I). Name and address
(in block Letters)

: S. RAMALINGAM,
5/1, SURYA APARTMENTS,
(BACKSIDE OF VINAYAKA SCHOOL),
LAKSHMI ROAD,
ADVAITHA ASHRAMAM ROAD,
FAIRLANDS, SALEM - 4.

(II). Engineering Qualification
Professional Qualification


: M.E.,
: F.I.V., M.I.E.,

(III). Class I A Panel Engineer - Tamil Nadu Public Building Act for issuing soundness Certificate to school buildings.

(IV). Number of years of experience
and nature thereof.

- ☐ 43 Years in private construction industry. Presently engaged in consultancy and valuation works.
- ☐ Chartered Civil Engineer.
- ☐ Competent Person Under Factory Act.
- ☐ Registered Valuer of Income Tax Department & IBBI
- ☐ Approved Panel Engineer for Banks.

Note : This certificate will not hold good in the event of
a. Any Fire Accident
b. Earthquake or any other natural calamity
c. Electrical short circuiting / Electrical defects


CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

Station : Salem

Signature of the Certifying Engineer.



Dated : 24.11.2025

Ref : ST-ZZEN INDIA PUBLIC SCHOOL-A8497



PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

24.11.2025



Er. S. RAMALINGAM M.E., F.I.V., M.I.E.,
Chartered Engineer M/108321/4-1993,
Class IA Panel Engineer,
(TN Public Buildings Act.)
5/1, Surya Apartments, Lakshmi Road,
Advathiha Ashramam Road,
Fairlands, Salem-636 004.



View of the Building



View of the Stage



Class Room Inside View



AARVY ASSOCIATES



[Signature]


CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
 SEELANAICKENPATTI BY-PASS,
 SALEM-636 201.

[Signature]


PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
 SEELANAICKENPATTI BY-PASS,
 SALEM-636 201.

Name of the School
ZZEN INDIA PUBLIC SCHOOL


ST-C8087-ZZEN INDIA PUBLIC SCHOOL-SEELANAICKENPATTI




Computer Lab Inside View



View of the Corridor



View of the Corridor & CCTV Camera
Fire Extinguisher



View of the Basket Ball Ground



AARVY ASSOCIATES



[Signature]


CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

[Signature]


PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

Name of the School
ZZEN INDIA PUBLIC SCHOOL


SALEM-636 201. ZZEN INDIA PUBLIC SCHOOL-SEELANAICKENPATTI




Play Ground



View of Toilet



View of the Staircase & Fire Extinguisher



Inside View of the Toilet



[Handwritten signature]

CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
 SEELANAICKENPATTI BY-PASS,
 SALEM-636 201.

D. Phuranes

PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
 SEELANAICKENPATTI BY-PASS,
 SALEM-636 201.

Name of the School
ZZEN INDIA PUBLIC SCHOOL

ST-C8087-ZZEN INDIA PUBLIC SCHOOL-SEELANAICKENPATTI

PROCEEDINGS OF THE COLLECTOR, SALEM.

PRESENT: DR. J. RADHAKRISHNAN, I.A.S.,

D.Dis. 11081/2000/H1,

Dated: 6.11.2001

Su b:- Tamil Nadu Public Buildings Licensing Act 1965 - Inclusion of the name of Thiru. S. Ramalingam in the panel of private practising Engineers - under Class - IA category in Salem District - Regarding.


- Ref:- 1. Thiru. S. Ramalingam petition dated: 7.2.2000.
2. Salem Superintending Engineer (PWD) Lr.No. 74M/CO22/EVA2/2001, dated: 19.2.2001.
3. This Office Proceedings D.Dis. 24947/94 /H2, dated: 31.3.94.
4. Chennai Chief Engineer (General) PWD Lr.AER/T1/JE/46507/2001, dated: 24.9.2001.

....

ORDER:

Thiru. S. Ramalingam, B.E., a Private Engineer, has applied for the inclusion of his name under category of Class IA in the panel of private practising Engineers maintained in this office for the purpose of issuing structural soundness certificate for public buildings in Salem District under the rules of Tamilnadu Public Building Licensing Act 1965.


2. The Chief Engineer, Public Works Department (General) Madras in the reference 4th cited has stated that the Board of Engineers in their 414th meeting held on 29.8.2001 have decided that the name of Thiru. S. Ramalingam, B.E., Private Engineer be included under the category of Class IA buildings the cost of which exceeds Rs. 10/- lakhs for the purpose of issuing structural soundness Certificate for public buildings in Salem District under the purview of the Tamil Nadu Public Buildings Licensing Act 1965.


CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.



PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.

:: 2 ::


3. In accordance with the instructions issued by the Chief Engineer (General) Public Works Department, Chennai in the reference fourth cited, the name of Thiru. S. Ramalingam, B.E., residing at 79-C1, Sivam Complex, Peramanoor, Salem-7 is included under the category of Class IA (for buildings the cost of which exceeds Rs.10/- Lakhs for the purpose of issuing structural soundness certificate for the Public Buildings in Salem District under the purview of the Tamilnadu Public Buildings Licensing Act 1965.



For Collector, Salem.

To


Thiru. S. Ramalingam, B.E.,
79-C1, Sivam Complex,
Peramanoor, Salem - 7.

Copy to H1 (stock file)


CORRESPONDENT
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.


PRINCIPAL
ZZEN INDIA PUBLIC SCHOOL
SEELANAICKENPATTI BY-PASS,
SALEM-636 201.